

Analysis Certificate silica sand - Ascom

Type 1 0.8 mm

Sand Sieve analysis	
+1000 μm	0
+850 μm	0
+600 μm	5
+425 μm	34.7
+300 μm	40.6
+150 μm	15.9
+125 μm	1.15
+106 μm	1.7

Type 1

Chemical Analysis	
SiO_2	99.520
Fe_2O_3	0.015
Al_2O_3	0.191
TiO_2	0.015
CaO	0.018
MgO	0.002